



Product Service

# CERTIFICATE

No. Z2 09 10 71565 004

**Holder of Certificate:** ZHEJIANG ZG-CELLS CO., LTD

No. 8, Huawei Road  
 Zhongshan Industrial Park, Pujiang  
 322204 Jinhua City, Zhejiang  
 PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:**



**Product:**

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules  
 Mono-crystalline Silicon Photovoltaic module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.:

704060924402-00

Date, 2009-10-13

Page 1 of 2

*Robert Fute*





Product Service

**CERTIFICATE**

No. Z2 09 10 71565 004

**Model(s):** ZG-160M, ZG-165M, ZG-170M, ZG-175M,  
ZG-180M, ZG-185M, ZG-190M

**Parameters:**

Rated Output Power at STC:	160W [ZG-160M] 165W [ZG-165M] 170W [ZG-170M] 175W [ZG-175M] 180W [ZG-180M] 185W [ZG-185M] 190W [ZG-190M]
Construction:	Framed, with junction box, cable and connectors.
Test Laboratory:	Eurotest Laboratori Srl Via dell'Industria, 18-35020 BRUGINE (PD) ITALY
Application Class:	Class A
Maximum System Voltage:	1000V DC

Remark:(\*)Fire Test MST 23 was not performed.

**Tested according to:**

- IEC 61215:2005
- EN 61215:2005
- IEC 61730-1:2004
- EN 61730-1:2007
- (\*) IEC 61730-2:2004
- EN 61730-2:2007

**Production Facility(ies):** 71565

Page 2 of 2



Product Service

# Attestation of Conformity

No. N8 09 10 71565 003

**Holder of Certificate: ZHEJIANG ZG-CELLS CO., LTD**

No 8, Huawei Road  
Zhongshan Industrial Park, Pujiang  
322204 Jinhua City Zhejiang  
PEOPLE'S REPUBLIC OF CHINA

**Product:**

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules  
Mono-crystalline Silicon Photovoltaic module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 704060924402-00

Date, 2009-10-13



After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2